

4500000, Precast Prestressed Concrete Construction
Response to Comments from Industry Review

Melissa Hollis
850-414-4182
melissa.hollis@dot.state.fl.us

Comment:

Per Sam's request, item group 450-2 was established. Please update the compensation information to include the new items.

Response;

The change has been made.

Anjani Girwarr
(863) 519-2825

Comment:

Why should this requirement be removed from section 450-1 on page 2 of 28?

~~At the beginning of each project, provide a notarized statement to the Engineer from a company designated representative certifying that the plant will manufacture the products in accordance with the requirements set forth in the Contract Documents and plant's approved Quality Control Plan. The Quality Control Manager's stamp on each product indicates certification that the product was fabricated in conformance with the Contractor's Quality Control Plan, the Contract, and this Section. Ensure that each shipment of precast concrete products to the project site is accompanied with a signed or stamped delivery ticket providing the description and the list of the products.~~

Same on page 23 of 28:

Response;

This statement was removed to eliminate duplication.

450-13.1.1 Product Acceptance on the Project: Use only non-shrink grout that are listed on the Qualified Products List.

~~Provide to the Engineer a manufacturer's certification conforming to the requirements of Section 6, which confirms that each product meets the requirements of this Section~~

Response:

This statement was removed to eliminate the certification requirement for QPL items.

Paul Wabi
Orlando Construction
(407)-482-7822

Comment:

Section 450-1 and 450-16.3 have very similar statements, but the statement in section 450-1 seems to be going away as the statement has been strikethrough. “ Similar statements exit, but same proposed for deletion in 450-1: 450-1 At the beginning of each project, provide a notarized statement to the Engineer from a company designated representative certifying that the plant will manufacture the products in accordance with the requirements set forth in the Contract Documents and plant’s approved Quality Control Plan. 450-16.3 At the beginning of each project, provide a notarized statement to the Engineer from a responsible company representative certifying that the plant will manufacture the products in accordance with the requirements set forth in the Contract Documents and plant’s Quality Control Plan.

Response:

The statement in 450-1 was removed to eliminate duplication within the Articles.

Chris Papastratis
(954) 777-4193 work
chris.papastratis@dot.state.fl.us

Comment:

Pertaining to the 4th paragraph under 450-1, we don’t agree with removing “Ensure that each shipment of precast concrete products to the project site is accompanied with a signed or stamped delivery ticket providing the description and the list of the products”. We inspect these delivery tickets onsite for content and accuracy of the load. The delivery tickets also contains additional information necessary for the verification of the product which is not obtained on the required QCM stamp.

Response:

This same statement is in 450-16.3 and has not been deleted. The statement in 450-1 was deleted to eliminate duplication.