

556 JACK AND BORE – MATERIALS.
(REV 3-9-09) (FA 3-30-09) (1-10)

TABLE 556-2-2 (Page 636). The reference to ASTM C 79 for Non-Pressure Reinforced Concrete Pipe (RCP) is changed to ASTM C 76, and the reference to ASCE xx 97 is deleted.

Table 556-2.2 Material Standards Acceptable for J&B and MT Installations		
Material Type	Non-Pressure	Pressure
Ductile Iron (DI)	AWWA C150/C151 ASTM A716, A747	AWWA C150/C151
Fiberglass Reinforced Polymer Mortar (FRPM)	ASTM D 3262	ASTM D 3517 AWWA C950
Polymer Concrete (PC)	DIN 54815-1 & 2	N/A
Prestressed Concrete Cylinder Pipe (PCCP)	N/A	AWWA C300
Reinforced Concrete Cylinder Pipe (RCCP)	N/A	ASTM C361
Reinforced Concrete Pipe (RCP)	ASTM C 76	ASTM C361 AWWA C300/C302
Steel	ASTM A139 Grade B ⁽¹⁾ API 2B ⁽²⁾	AWWA C200 API 2B ⁽²⁾
Polyvinyl Chloride (PVC)	ASTM D 1785	N/A
Polyethylene (PE)	ASTM D 2447 ASTM D 2513 FOR GAS > 3 Inches	N/A
Polybutylene (PB)	ASTM D 2662	N/A
Cellulose Acetate Butyrate (CAB)	ASTM D 1503	N/A
Acrylonitrile Butadiene Styrene (ABS)	ASTM D 1527	N/A
Reinforced Thermosetting Resin Pipe (RTRP)	ASTM D 2296 OR ASTM D2997	N/A

⁽¹⁾ No hydrostatic test required
⁽²⁾ Dimensional tolerances only