

EXPECTED IMPLEMENTATION JANUARY 2012

556 JACK AND BORE. (REV 5-23-11) (FA 6-10-11) (1-12)

ARTICLE 556-2 (Pages 701 – 704) Table 556-2.2 is deleted and the following substituted:

Table 556-2.2 Material Standards Acceptable for J&B and MT Installations		
Material Type	Non-Pressure	Pressure
Ductile Iron (DI)	AWWA C150/C151 ASTM A716	AWWA C150/C151
Fiberglass Reinforced Polymer Mortar (FRPM)	ASTM D 3262	ASTM D 3517 AWWA C950
Polymer Concrete (PC)	DIN 54815-1 & 2	N/A
Prestressed Concrete Cylinder Pipe (PCCP)	N/A	AWWA C301
Reinforced Concrete Cylinder Pipe (RCCP)	N/A	ASTM C361
Reinforced Concrete Pipe (RCP)	ASTM C 76	ASTM C361 AWWA C300/C302
Steel	ASTM A139 Grade B ⁽¹⁾ API 2B ⁽²⁾	AWWA C200 API 2B ⁽²⁾
Polyvinyl Chloride (PVC)	ASTM D 1785	N/A
Acrylonitrile Butadiene Styrene (ABS)	ASTM D 1527	N/A
Reinforced Thermosetting Resin Pipe (RTRP)	ASTM D 2996 OR ASTM D2997	N/A
⁽¹⁾ No hydrostatic test required		
⁽²⁾ Dimensional tolerances only		

SUBARTICLE 556-3.1 (Page 704) is deleted and the following substituted:

556-3.1 Pedestrian Traffic: When and where installations temporarily disrupt use of a pedestrian way, provide a safe alternate route in accordance with Design Standards, Index Nos. 600 and 660.