

4300100 PIPE CULVERTS
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

.....
Kenneth Lane
904-759-1523
kenneth.lane@dot.state.fl.us

Comment: (6-5-14)

In my opinion no metal pipe should be allowed in the FDOT system due to the issues of metal pipe failures we have in the Jacksonville area.

The salinity in the soils of our area has caused several severe failures of new pipe.

Response: Thanks for your input. We understand your concern; however, there are many sites throughout the state with soil conditions suitable for metallic culverts. Your comments will be forwarded to the State Drainage Office.

No change made.
