## 5480906 RETAINING WALL SYSTEMS COMMENTS FROM INTERNAL/INDUSTRY REVIEW

## Larry Jones 414-4305 larry.jones@dot.state.fl.us

Comment: (5-22-14)

Organic Contenta	One per soil type¤	One per soil type¤
<i>pH</i> ¤	One-per-soil-type¤	One-per-soil-type¤
Direct·Shear¤	Three per soil type when required by 548-9.5¤	One per soil type¤

It seems the attached would be easier to implement and enforce.

Response: Agree. Change Made.

\*

Ben Watson 352-955-2935 ben.watson@dot.state.fl.us

Comment: (6-9-14)

Suggest removing the pH from the table and write in the specification that acceptance pH testing is to be sampled at the point of placement.

Response:

\*