

ORIGINATION FORM

Date: **5/6/2014**

Originator: **Paul Vinik**

Contact Information: **352-955-6686, paul.vinik@dot.state.fl.us**

Specification Title: **Specification Title: Section 931 Metal Accessory Materials for Concrete Pavement and Concrete Structures**

Specification Section, Article, or Subarticle Number: **931-3.6**

Why does the existing language need to be changed? **SSPC Paint 25 has been discontinued.**

Summary of the changes: **Changed SSPC Paint 25 to SSPC Paint 104**

Are these changes applicable to all Department jobs? **Yes**

If not, what are the restrictions?

Will these changes result in an increase or decrease in project costs? **No**

If yes, what is the estimated change in costs?

With who have you discussed these changes?

What other offices will be impacted by these changes? **No**

Are changes needed to the PPM, Design Standards, SDG, CPAM or other manual? **No**

Are all references to external publications current? **Yes**

If not, what references need to be updated (please include changes in the redline)?

Is a Design Bulletin, Construction Memo, or Estimates Bulletin needed? **No**

Contact the State Specifications Office for assistance in completing this form.

Daniel Scheer 850-414-4130 daniel.scheer@dot.state.fl.us

Frances Thomas 850-414-4101 frances.thomas@dot.state.fl.us

Debbie Toole 850-414-4114 deborah.toole@dot.state.fl.us

Andy Harper 850-414-4127 clifton.harper@dot.state.fl.us

Ray Haverty 850-414-4129 ray.haverty@dot.state.fl.us



Florida Department of Transportation

RICK SCOTT
GOVERNOR

605 Suwannee Street
Tallahassee, FL 32399-0450

ANANTH PRASAD, P.E.
SECRETARY

MEMORANDUM

DATE: May 30, 2014

TO: Specification Review Distribution List

FROM: Daniel Scheer, P.E., State Specifications Engineer

SUBJECT: Proposed Specification: **9310306 Metal Accessory Materials For Concrete Pavement And Concrete Structures.**

In accordance with Specification Development Procedures, we are sending you a copy of a proposed specification change.

This change was proposed by Paul Vinik of the Department's State Materials Office (SMO) to update an industry standard.

Please share this proposal with others within your responsibility. Review comments are due within four weeks and should be sent to Mail Station 75 or to my attention via e-mail at SP965DS, or daniel.scheer@dot.state.fl.us. Comments received after **June 27, 2014**, may not be considered. Your input is encouraged.

DS/dt
Attachment

METAL ACCESSORY MATERIALS FOR CONCRETE PAVEMENT AND CONCRETE STRUCTURES.**(REV 5-6-14)**

SUBARTICLE 931-3.6 is deleted and the following substituted:

931-3.6 Materials: The wire for the welded assembly shall be in accordance with all applicable requirements of ASTM A82.

After fabrication, apply one coat of alkyd primer meeting the material requirements of SSPC Paint ~~25~~*104*. Apply the primer in accordance with the manufacturer's recommendations.