

9430000 CORRUGATED STEEL PIPE AND PIPE ARCH (INCLUDING UNDERDRAIN)
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

.....
Dan Hurtado
414-4155
dan.hurtado@dot.state.fl.us

Comment: (6-4-14)

1. Recommend removing the requirement to have the certification notarized. We don't gain anything from this.

Response:

2. The Spec requires that the testing of pipe joints and gaskets to be done in the presence of the Engineer.

a. Are these tests done at the job site or the fabrication facility?

Response:

b. If they are done at the fabrication facility, do we have an inspection presence there?

Response:

c. What if they are done out of state?

Response:

Kenneth Lane
904-759-1523
kenneth.lane@dot.state.fl.us

Comment: (6-5-14)

In my opinion no metal pipe should be allowed in the FDOT system due to the issues of metal pipe failures we have in the Jacksonville area.

The salinity in the soils of our area has caused several severe failures of new pipe.

Response:

Rod Powers
352-222-6430
rodneypowers@hotmail.com

Comment: (6-25-14)

943-1, last paragraph: The proposed revision seems to single-out metal pipe as having a unique special testing requirement. We agree with the revision except that the same requirement should be simultaneously implemented for all pipe types.

hugger band or associated hardware. Testing *of pipe joints* shall be witnessed by the Engineer. ¶
→ *Test the gaskets in accordance with ASTM D3212. Testing of gaskets shall be witnessed by the Engineer.* ¶

Response:
