

5630000 – ANTI-GRAFFITI COATING SYSTEM
Comments Received From Industry Review

Richard Newsome

File: 5630000 - Anti-Graffiti Coating System
Username: Richard Newsome
UserTel: 407-482-7829
Date: Wednesday, March 08, 2006
Time: 08:06:42 AM

Comments:

The Last Sentence in Article 563-2-2 Protection of adjacent Surfaces, should read:

"Clean surfaces other than those intended to be coated until all traces of anti-graffiti coating has been removed and the surface has an acceptable appearance."

Tonii Brush

File: 5630000 - Anti-Graffiti Coating System
Username: Tonii Brush
UserTel: 386-943-5348
Date: Wednesday, March 08, 2006
Time: 08:04:42 AM

Comments:

In the spec shown below the English measure is struck through and the metric left. In the other specs the metric is struck through and the English left. Is there a reason to leave the metric measure and not the English?

Chris Lovelace

COMMENTS: Remove 563.2.2, line 2, sentence that reads "Clean surfaces that are to be coated...acceptable appearance." It makes no sense in its current context.

Remove 'Moisture in Concrete...ASTM D 4263' from 563.2.3. The test is inadequate at best in real world DOT situations. Insert acceptable use of electronic moisture meters.

Adhesion testing required under 560-15 (line 9 in 563.2.3) should be conducted before the test patch is applied as well as after coating application.

In 563.2.7, line 2, delete 'receiving' and insert 'that have received new' instead.

Submitted by: Chris Lovelace, KTA-Tator, Inc.

Phone #: 954-575-1640

Tony Walsh

File: 5630000 - Anti-Graffiti Coating System
Username Tony Walsh
UserTel: 386-258-4459
Date: Monday, March 27, 2006
Time: 07:35:12 AM

Comments:

In section 563-2.2, Protection of Adjacent Surfaces. In the second paragraph, second sentence, it reads "Clean surfaces that are to be coated, as to manufacturer's recommendation....". since this is a "protection" section, shouldn't it read "Clean surfaces that are to be protected ..."

Jennifer Taylor

File: 5630000 - Anti-Graffiti Coating System
Username: Jennifer Taylor
UserTel: 386-740-3471
Date: Wednesday, March 29, 2006
Time: 07:35:37 AM

Comments:

A majority of the Anti-Graffiti coating systems are applied over a class 5 finish coating. The manufacturer of the class 5 finish coating system should be responsible for supplying an Anti-Graffiti coating system that is compatible to their system, when a Anti-Graffiti coating system is called for in the plans. Eliminate section 563 as recommended and require the manufacturer of the Class 5 coating system to supply an Anti-Graffiti coating system meeting the requirements of sections 563 & 975-9 and include it under section 400-15.2.6 when called for in the plans.

Jose Rodriguez

File: 5630000 - Anti-Graffiti Coating System
Username: Jose Rodriguez
UserEmail: jose.rodriguez@dot.state.fl.us
UserTel: Suncom 512-7595
UserFAX: Suncom 512-7614
Date: Thursday, March 30, 2006
Time: 10:17:29 AM

Comments:

Section 563-3:

Need to clarify the meaning of "projected surface". For example, for a round column, is the area to be measured the diameter of the column times the height (projected area on a vertical plane) or the perimeter times the height (actual area)?