

1250801 EXCAVATION FOR STRUCTURES AND PIPE  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

---

Howie Moseley  
386-961-7853  
[howard.moseley@dot.state.fl.us](mailto:howard.moseley@dot.state.fl.us)

Comment: (12-20-12)

I have concerns with reducing the density requirement from 100% to 95% of a standard proctor for all pipes when the pipe is beneath the roadway. There are several roads in our District where depressions have developed above pipe in the roadway (SR 207 b/n Palatka and Hastings is an example). This specification could lead to more of these pavement failures. A better solution would be to only allow pipe that can be safely compacted to 100% of the standard proctor under the roadway.

**Response:**

\*\*\*\*\*