

5560700 Jack and Bore.
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Geoff Scales

gmscales@LaneConstruct.com

Comment: (12-12-12) Too combine jacked and bored casings with the storm sewer or conduit items, seems regressive. The cost of jacking versus open placement is several times greater, and in the case where work orders or plan quantity changes add or delete sewer or conduit quantity, the unit price may be meaningless, because it will presumably include a varying proportion of jacked and open cut placement.

Response:

Paul Harkins

paul.harkins@dot.state.fl.us

Comment: (12-12-12) Too better understand would it not be helpful to have the changes to SECTION 430 and 630 submitted to coincide with this change. Is the intent to now pay for each item separately, casing, grout, drainage pipe, etc?

Response:

Woerner, Bert

bert.woerner@dot.state.fl.us

Comment: (1-8-13) For the last sentence of 556-7 Compensation:
It is unclear if we are to withhold payment for all Jack and Bores or just the one you do not have the bore report for. Consider the following sentence instead:
“No compensation will be made for the **Pay item associated** with the jack and bore until a Bore Path Report has been delivered to the Engineer.”

Response:
