## **EXPECTED IMPLEMENTATION JULY 2014**



125 EXCAVATION FOR STRUCTURES AND PIPE.

(REV 12-5-13) (FA 1-15-14) (7-14)

SUBARTICLE 125-9.2.2 is deleted and the following substituted:

125-9.2.2 Exceptions to Structures and Pipe Density Requirements: Compact the backfill to a firmness approximately equal to that of the soil next to the pipe trench in locations outside the plane described by a two (horizontal) to one (vertical) slope downward from the roadway shoulder line or the gutter line as applicable. Apply 125-9.2.1 when compacting side-drain pipe backfill under driveways serving a property that is not a single residential lot.







