

1600302 STABILIZING  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

---

Shailesh Patel, D5 Const.  
386-943-5347  
[shailesh.patel@dot.state.fl.us](mailto:shailesh.patel@dot.state.fl.us)

Comment: (12-13-13)

Please add the highlighted text:

**160-3.2 Application of Stabilizing Material:** After substantially completing the roadbed grading operations, determine the type and quantity (if any) of stabilizing material necessary for compliance with the bearing value requirements. *Before using any Fossil Fuel Combustion Products (FFCPs), provide documentation, at the preconstruction meeting, signed and sealed by the Specialty Engineer that these materials meet the requirements of 403.7047F.S.* Notify the Engineer of the approximate quantity to be added before spreading. When additive stabilizing materials are required, spread the material uniformly over the area to be stabilized.

Response:

\*\*\*\*\*