

3530901 CONCRETE PAVEMENT SLAB REPLACEMENT
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Scheer, Daniel
850-414-4130

Comment: (10-8-13) Recommend we modify 353-11 with the following:

353-11 Method of Measurement.

The pay quantity, *calculated using field-measured horizontal dimensions and thickness of the removed slab*, will be the volume, in cubic yards, of *calculated* concrete *volume* placed and accepted ~~determined by calculation. The quantity will be calculated using field-measured horizontal dimensions and thickness of the removed slab.~~ *The pay quantity for cleaning and sealing joints will be in accordance with 350-17.*

Response: Suggested changes are acceptable.
Changes made.
