

EXPECTED IMPLEMENTATION JULY 2014

D

430 PIPE CULVERTS.
(REV 11-14-13) (FA 2-18-14) (7-14)

SUBARTICLE 430-2.1 is deleted and the following substituted:

430-2.1 Pipe: Meet the following requirements:

Concrete Pipe	Section 449
Round Rubber Gaskets	Section 942
Corrugated Steel Pipe and Pipe Arch.....	Section 943
Corrugated Aluminum Pipe and Pipe Arch	Section 945
Corrugated Polyethylene Pipe.....	Section 948
Steel Reinforced Polyethylene Ribbed Pipe	Section 948
Polyvinyl Chloride (PVC) Pipe	Section 948
Fiberglass Reinforced Polymer Pipe.....	Section 948
Polypropylene Pipe	Section 948

R

ARTICLE 460-9 is deleted and the following substituted:

430-9 Specific Requirements for Steel Reinforced Polyethylene Ribbed Pipe, Corrugated Polyethylene Pipe, Polypropylene Pipe, and Polyvinyl Chloride (PVC) Pipe.

430-9.1 Field Joints: Use gasketed joints to seal side drain, and storm and cross drain. Use gaskets meeting the requirements of Section 449. Ensure that the pipe manufacturer provides a joint design approved by the Engineer before use.

430-9.2 Installation Requirements Including Trenching, Foundation and Backfilling Operations: Check structure shape regularly during backfilling to verify acceptability of the construction method used.

Replace pipe deflected 5% or more of the certified actual mean diameter of the pipe at final inspection at no cost to the Department.

A

F

T