

4310402 PIPE LINER  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

---

Art Berger  
414-5368  
[arthur.berger@dot.state.fl.us](mailto:arthur.berger@dot.state.fl.us)

Comment: (12-11-13)

Should the following text be added: *Give priority to the manufacturer's installation instructions if required by the warranty*?"

Response: This question should be answered by the specifications office. I am not sure if this would lead to any benefit.

(From the Specs Office - The Engineer has the option/responsibility of determining if the manufacturer's instruction should be used in lieu of ASTM F585. He/She is aware of any conditions that would warrant this. No change made.

\*\*\*\*\*

Patel, Shailesh  
[shailesh.patel@dot.state.fl.us](mailto:shailesh.patel@dot.state.fl.us)

Comment: (1-6-14)

431-4.2.5 Steel Reinforced Polyethylene ~~Ribbed Pipe~~. Install reinforced pipe (Delete "Ribbed Pipe").

Response: Both ASTM and AASHTO documents refer to this pipe as "ribbed pipe", changing it in this specification will lead to inconsistencies between our specification and the national documents. No change made.

\*\*\*\*\*