

4490200 Precast Concrete Drainage Products
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Gevin J. McDaniel, P.E.
Senior Structures Design Engineer

Comment: (10-17-13) Please consider allowing either ASTM 1064 or ASTM A706 wires for Site Cage Machines.

Response:

Gevin J. McDaniel, P.E.
Senior Structures Design Engineer

Comment: (10-17-13) The ASTM requirements should only be listed in Section 931. All other sections should refer to 931 instead of the ASTM.

Response:
