

5480203 RETAINING WALL SYSTEMS
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Geoff Scales
geoff.scales@cardno.com

Comment: (10-28-13) The sentence 'Use longitudinal and transverse wires of equal and diameter within a given piece of mesh reinforcement.' is missing a word somewhere, can't tell exactly what it is supposed to be, but it's missing.

Response: Thanks for the comment. Yes, the missing word is “constant”. The comment will be incorporated into the modified version.

Bob Dion

Comment: (10-29-13)
The last portion of the second sentence in the second paragraph is an incomplete thought 'or by testing temperature match cured cylinders'.

Response: Thanks for the comment. The last phrase is part of the sentence. Two type of testing has been mentioned

- (1) *Testing compressive strength cylinders that are cured under the conditions similar to the product or*
- (2) *Testing temperature- match- cured cylinders.*

No changes are needed.
