

# EXPECTED IMPLEMENTATION JULY 2014

## **671 TRAFFIC CONTROLLERS.** **(REV 11-25-13) (FA 1-22-14) (7-14)**

SECTION 671 is deleted and the following substituted:

### **SECTION 671** **TRAFFIC CONTROLLERS**

#### **671-1 Description.**

Furnish and install a NEMA Model 170, Model 2070, or ATC controller unit as shown in the Plans. Meet the requirements of Section 603.

#### **671-2 Materials.**

Use traffic controllers listed on the Department's Approved Product List (APL). Ensure equipment is permanently marked with the manufacturer's name or trademark, part number, and serial number.

Controllers must meet the following applicable industry standards:

NEMA TS1 Controller .....	NEMA TS-1-1989
NEMA TS2 Controller .....	NEMA TS-2-2003
Model 170 Controller .....	CALTRANS TEES, 2009
Model 2070 Controller .....	CALTRANS TEES, 2009
ATC Controller .....	AASHTO/ITE/NEMA ATC 5.2b

All controllers must provide functionality that meets or exceeds operational characteristics, including NTCIP support, as described in NEMA TS-2-2003.

#### **671-3 Method of Measurement.**

No separate payment will be made for the controller; payment is included with the Traffic Controller Assembly.