

1050302-MM9.2 CONTRACTOR QUALITY CONTROL GENERAL REQUIREMENTS -
COMPLIANCE WITH THE MATERIALS MANUAL
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Katie Bettman
904-360-5391
katie.bettman@dot.state.fl.us

Comments: (12-12-12)

1) Should the following specific chloride requirements be in the Chloride Section? "Enter all required documentation and test results of the chloride test in the Department database. Chloride test results shall be entered into the Department's database within 72 hours of obtaining the chloride test results. Failure to comply with the time frame for data entry may be cause for suspension of the QC Plan."

Response:

2) Can we require a timeframe for when the sample information is entered into MAC?

Response:

3) I thought the hot weather requirements were going to be removed from 9.2.7.4 Hot Weather concrete trial mix for Specifications Section 353 (slab replacement).

Response:

Jose Kandarappallil
772-429-4936
Kandarappallil.Jose@dot.state.fl.us

Comments: (12-16-14)

1. 9.2.15.2 – Recommend changing “reinforced concrete” in the first sentence to “Structural concrete”.

Response:
