

EXPECTED IMPLEMENTATION JULY 2015

ENGINEER'S FIELD OFFICE.

(REV 9-10-14) (FA 11-13-14) (7-15)

SUBARTICLE 109-2.1 is deleted and the following substituted:

109-2.1 General Requirements: The field office shall be a building or mobile trailer erected at a location approved by the Engineer and shall be separate from any building used by the Contractor.

The office ceiling height shall be at least 7 feet with a minimum floor space as specified in the Plans. The total floor area shall be partitioned according to the following table:

Minimum Total Area Required	# of small rooms ¹	# of large rooms ²	# of restrooms
300 ft ²	1	1	-
600 ft ²	2	2	1
900 ft ²	3	2	1
1,200 ft ²	5	3	2
1,500 ft ²	6	4	2

1. Small rooms shall have a minimum floor area of 90 ft².
2. Large rooms shall have a minimum floor area of 150 ft².

Each room shall have at least one weatherproof window, two electrical outlets, one telephone outlet, and one Category 5 Ethernet outlet. Each window shall have a minimum area of 8 square feet, be screened and open and close to provide adequate ventilation. Equip each outside door with a lock. Provide 2 keys for each outside door lock suitable for duplication by the Engineer if additional keys are required.

The Engineer may approve an equivalent facility provided it meets the minimum specified requirements.