

4551501 STRUCTURES FOUNDATIONS
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Maria Connolly
954-934-1209
maria.connolly@dot.state.fl.us

Comments: (12-16-14)

Section 455-15.8.2 Polymer Slurry for Shafts for Sign, Signal, Lighting and ITS structures: Need to include the word "support" in the following sentence "Materials manufactured expressly for use as polymer slurry for drilled shafts may be used as slurry for drilled shaft excavations installed to support sign, signal, lighting and ITS structures".

Response:

Kaite Kehres (via Deborah Ihsan)
FDOT, D4
772-429-4889

Comments: (1-6-15)

Recommend revising the new last sentence for Section 455-15.7 Casings that states "Expandable or split casings that are removable are not permitted for use below the water," to state "Expandable or split casings that are removable are not permitted for use below the water surface."

Response:
