

## STATEWIDE CRITICAL REQUIREMENT LIST – FISCAL YEAR 2016/2017

### Quality Assessment Category Number 12B Lighting

1. Is CEI project staff aware they are required to enforce the following requirements: All materials used comply with the approved shop drawings? The seven day burn in period is completed satisfactorily. Provide 2 copies of the as-built plans to the maintaining agency before final acceptance. A project visit discussion with project staff and a review of project files verifies this. [Specs. 715-2, 715-14, 715-15, Index 17501 note 6]
2. Is CEI project staff aware of and enforcing the requirement that the Contractor install all lighting in accord with Indexes 17500 to 17515? Discussion with CEI staff and a review of lighting plans, shop drawings and a field visit verify this. [Indexes 17500 to 17515].