

## **STATEWIDE CRITICAL REQUIREMENT LIST – FISCAL YEAR 2017/2018**

### **Quality Assessment Category Number 12B Lighting**

1. Is CEI project staff aware they are required to enforce the following requirements?  
All materials used comply with the approved shop drawings and the seven day burn in period is completed satisfactorily. Two copies of the as-built plans are provided to the maintaining agency before final acceptance. A project visit discussion with project staff and a review of project files verifies this. [Specs. 715-2, 715-14, 715-15]
2. Is CEI project staff aware of and enforcing the requirement that the Contractor install all lighting in accordance with Indexes 17500 to 17515 and the Plans? Discussion with CEI staff and a review of lighting plans, shop drawings and a field visit verify this. [Indexes 17500 to 17515].